

Cable Glands

- ◆ Explosion protection to
 - CENELEC
 - IEC
 - NEC
- ◆ Can be used in
 - Zone 1 and Zone 2
 - Zone 21 and Zone 22
 - Class I, Zone 1 and Zone 2
 - Class I, Division 1, Groups A, B, C, D
 - Class I, Division 2, Groups A, B, C, D
- ◆ Ex d and Ex e versions
- ◆ Cable glands:
 - Suitable for armored or unarmored cable
 - Suitable for cable or steel pipe wiring



Explosion-proof cable glands include:

- 1) DQM-I (Ex e)
 - Plastic, unarmored
 - Metal, unarmored or armored
- 2) DQM-II (Ex d Ex e)
 - Metal, unarmored, single seal
 - Metal, armored, dual seal
 - Metal, armored, dual seal, "Cold Flow"
- 3) DQM-III (Ex d Ex e)
 - Metal, unarmored, compound barrier
 - Metal, armored, compound barrier



Zones 1&2; 21&22